



City of Miami

ADDENDUM NO. 1

September 22, 2015

INVITATION TO BID NO.: 14-15-029

GROVE PARK ROAD IMPROVEMENTS – PHASE 2 – D3

CITP PROJECT NO.: B-40347/B-30008A

TO: ALL PROSPECTIVE BIDDERS:


The following changes, additions, clarifications, and/or deletions amend the above-captioned Invitation to Bid and shall become an integral part of the Bids submitted and the Contract to be executed for Grove Park Road Improvements – Phase 2 – D3 - Invitation to Bid No.: 14-15-029 (the “Project”). Please note the contents herein and affix same to the documents you have on hand.

All attachments (if any) are available on the Capital Improvements and Transportation Program website and are part of this Addendum.

A. Requests for Information – Since Issuance of this Invitation to Bid on September 1, 2015:

- Q1.** Will the City consider extending the time period to achieve Substantial Completion?
A1. **Yes. The Contractor shall have One Hundred and Fifty (150) calendar days to achieve Substantial Completion from the date that the Notice to Proceed is issued. Contractor shall have an additional Thirty (30) calendar days after that to achieve Final Completion of the Contract.**
- Q2.** Will the City amend the Bid form to include an allowance for Off Duty Police Officers?
A2. **No. The Contractor will not be required to hire any off duty policemen to complete the scope of work for this Project.**
- Q3.** Who shall pay for the Density Tests required under the scope of work for this Project?
A3. **The Contractor shall pay for all tests required pursuant to the relevant Florida Department of Transportation and City of Miami specifications.**
- Q4.** Are there any soil reports available with respect to the designated Project area?
A4. **No. There are no soil reports available concerning the designated Project area.**
- Q5.** Can High Density Polyethylene (HDPE) solid & perforated pipe be utilized for this Project?
A5. **Yes. Solid and perforated HDPE pipe can be used to complete the work for this Project.**

THIS ADDENDUM IS AN ESSENTIAL PORTION OF THE CONTRACT DOCUMENT AND SHALL BE MADE A PART THEREOF.



Annie Perez, CPPO, Director of Procurement

This Addendum should be signed and dated by the Bidder and submitted as proof of receipt with the submission of their Bid. The Bidder by identifying the addendum number in their Bid and by signing and submission of their Bid shall serve as proof of receipt of this Addendum.

NAME OF FIRM: _____

DATE: _____

SIGNATURE: _____