



# City of Miami

## ADDENDUM NO. 1

March 29, 2018

INVITATION TO BID NO. 17-18-019

### GROVE PARK ROADWAY AND WATER MAIN IMPROVEMENTS - D3

#### OFFICE OF CAPITAL IMPROVEMENTS PROJECT NO. B-40347

TO: ALL PROSPECTIVE BIDDERS:

The following changes, additions, clarifications, and/or deletions amend the above-captioned Invitation to Bid, and shall become an integral part of the Bid submitted, and the Contract to be executed for the **Grove Park Roadway and Water Main Improvements, D3, Invitation To Bid ("ITB") No. 17-18-019, Project No. B-40347** (the "Project"). Please note the contents herein, and affix same to the documents you have on hand.

All attachments (if any) are available on the Capital Improvements Program's (CIP) website, and are part of this Addendum.

**A. Requests for information received and the corresponding responses:**

Q1. What is the cost estimate for the entire Project?

A1. **The engineer's cost estimate for the Roadway Improvements and the Water Main Improvements, combined, is \$1,958,221.**

Q2. The Water Main Bid Form has an item for Police Officers, but the City of Miami Bid Form does not. Is it possible to include an allowance for Off Duty Police Officers in City of Miami Bid Form?

A2. **In lieu of an "allowance" for off-duty police, the City of Miami Bid Form includes line item 102-1- Maintenance of Traffic to cover the cost of off-duty police and other related items.**

Q3. Is there a Geotechnical Report for the project site?

A3. **Yes. Please see Appendix "L" – Miami-Dade Water and Sewer Department Geotechnical Investigation (attached hereto as Exhibit 1).**

Q4. The quantities of Asphalt are confusing. The Water Main Bid Form has the quantities very clear (items #28 and #29). However, in the City of Miami Bid Form, Bid item 3-6 does not make sense. The quantities in the Sheet G-01 has more logical quantities.

A4. **The quantities on Sheet G-01 are accurate, Items 3-6 have been updated on the Revised City of Miami Bid Form (attached hereto as Exhibit 2). Pavement restoration shall be per**

**City of Miami Public Works Standards (R-3, Misc. 35-88-7, Sheet 1 of 1, attached hereto as Exhibit 3).**

---

**Q5.** The typical sections on sheet G-08 show no new roadway construction. Only Milling & Resurfacing. Please advise?

**A5.** **Pavement restoration shall be per the attached Exhibit 3. Full roadway reconstruction shall be limited to areas above drainage work and per Water Main plans. Please refer to response to Q5, above.**

---

**Q6.** Will the City of Miami accept a Certified Underground Utility Contractor licensed by the State of Florida to bid on the Grove Park Roadway and Water Main Improvements Project?

**A6.** **No. As stated in the Minimum Requirements on page 6 of the Contract Document, Bidders must have: i) a current certified General Contractor license issued by the State of Florida; or ii) a Miami-Dade County Certificate of Competency as a General Engineering Contractor.**

**B. Additional Information:**

1. **Exhibit 1, Appendix "L" – Miami-Dade Water and Sewer Department Geotechnical Investigation;**
2. **Exhibit 2, Revised Roadway Improvements Bid Form – Base Bid;**
3. **Exhibit 3, City of Miami Public Works Standards (R-3, Misc. 35-88-7, Sheet 1 of 1).**

**THIS ADDENDUM IS AN ESSENTIAL PORTION OF THE CONTRACT DOCUMENT AND SHALL BE MADE A PART THEREOF.**

  
\_\_\_\_\_  
**Annie Perez, CPPO, Director of Procurement**