



City of Miami

ADDENDUM No. 2

June 24, 2019

INVITATION TO BID No.: 18-19-019

LEGION PARK SEAWALL AND BOAT RAMP, D5 PROJECT No. B-40510

TO: ALL PROSPECTIVE BIDDERS:

The following changes, additions, clarifications, and/or deletions amend the above-captioned Invitation to Bid (ITB) and shall become an integral part of the Bid submitted and the Contract to be executed for **Legion Park Seawall and Boat Ramp, D5 - ITB No.: 18-19-019** (the "Project"). Please note the contents herein and affix same to the documents you have on hand.

All attachments (if any) are available on the Office of Capital Improvements (OCI) website, <http://www.miamigov.com/MiamiCapital/NewBidsandProposals.html>, and are part of this Addendum.

REQUESTS FOR INFORMATION:

- Q1. Concerning the Structural Notes on Sheet G4 - Specifically on Note # 10, which reads specifically:
- 10. Cut and Fill Operations
 - 10.2. Quantities for cut and fill shown in these plans are approximate and shall be verified by the contractor before bidding.
 - 10.3. Any excavated material that is deemed by the engineer unsuitable for filling shall be properly disposed of by the contractor at an approved facility or dumpsite. The cost for disposal of unsuitable material shall be included in the cost of cut and fill.

Can the City provide an estimated quantity amount so that we can use that and include in our bid?
- A1. The excavation and disposal of unsuitable material is included in the lump sum price, and we estimate approximately 40 Cubic Yards ("CY") of excavation.
-
- Q2. Reinforcing Sheet Pile - There is no detail in the plans on the reinforcing on the concrete sheet pile. Are you providing this material or is this a design build?
- A2. Please refer to notes on sheet S-5 and S-6. Concrete sheet piles to be fabricated following FDOT index 6040. Contractor to submit S&S shop drawings for EOR's approval.


Q3. Please provide pile length for the 12" diameter Polyethylene sleeved piles for the dock.

A3. The proposed tip elevation for the woodpiles is -32.00 (City of Miami Datum).

CLARIFICATIONS:

1. The "**Boundary and Topographic Survey**" is updated and attached to this Addendum as "**Attachment No. 1 - Updated Survey.**"

THIS ADDENDUM IS AN ESSENTIAL PORTION OF THE CONTRACT DOCUMENT AND SHALL BE MADE A PART THEREOF.



**Annie Perez, CPPO, Director
City of Miami Department of Procurement**