

From: [Wilson, Carol \(MDT\)](#)
To: [Claudia Diaz](#)
Cc: [Smerling, Barry \(MDT\)](#)
Subject: RE: Mary Brickell Village - Review
Date: Monday, June 08, 2015 2:15:02 PM

Miami-Dade Transit (MDT) staff reviewed the plans and has no objections of the City of Miami's Mary Brickell Village Drainage and Roadway Improvements, Phase One, as submitted. However, if changes are made to the plans in the vicinity of the MDT corridor, it must be re-submitted to MDT staff for review. Again, thank you for sharing the City of Miami Plans with us.

In light of such, you are reminded that it will require getting authorization access from MDT to work near its rail corridor, Regards!

Carol A. Wilson, PLS
Manager, Right-of-Way engineering
Miami-Dade Transit
701 NW 1st Street, 15th Floor
Miami, Florida 33136
Tel. 786-469-5278

"Delivering Excellence Everyday"

From: Claudia Diaz [mailto:claudia.diaz@tylin.com]
Sent: Monday, June 08, 2015 11:15 AM
To: Wilson, Carol (MDT)
Subject: RE: Mary Brickell Village - Review

Good Morning Carol,

As per our conversation 2 weeks ago, please send me the email with MDT approval of the design plans. To forward to the City of Miami and be able to proceed with the Bid.

Sincerely,

Claudia Diaz, P.E.
Transportation Engineer
TYLIN INTERNATIONAL
201 Alhambra Circle, Suite 900
Coral Gables, FL 33134
305.567.1888 (Main)
305.714.4018 (Direct)
305.567.1771 Fax
claudia.diaz@tylin.com

Visit us online at www.tylin.com
[Twitter](#) | [Facebook](#) | [LinkedIn](#) | [YouTube](#)

From: Wilson, Carol (MDT) [<mailto:carolw@miamidade.gov>]
Sent: Thursday, May 21, 2015 2:42 PM
To: Claudia Diaz
Subject: RE: Mary Brickell Village - Review

Claudia, who is applying for the access to work near or within the Metrorail/Metromover Corridors?
Please advise so I can send them the application. Thank you!

From: Claudia Diaz [<mailto:claudia.diaz@tylin.com>]
Sent: Wednesday, May 20, 2015 1:11 PM
To: Amores, Daniela (MDT); Wilson, Carol (MDT)
Cc: Misas, Orlando
Subject: RE: Mary Brickell Village - Review

Good afternoon all,

I'm not sure if the attached email is from the Mover people. But we did incorporated the notes to the plans.

Please refer to the attachment. I provided responses to all the comments that we received from Carol and this is the only one that actually needed to be in the plans.

If this is ok. When do you think the City can get the MDT approval?

With this approval the city will be able to then send the plans to bid, and then select the contractor that will produce the MOT plans that will also be submitted to MDT for review.

Please advise.

Sincerely,

Claudia Diaz, P.E.
Transportation Engineer
TYLIN INTERNATIONAL
201 Alhambra Circle, Suite 900
Coral Gables, FL 33134
305.567.1888 (Main)
305.714.4018 (Direct)
305.567.1771 Fax
claudia.diaz@tylin.com
Visit us online at www.tylin.com
[Twitter](#) | [Facebook](#) | [LinkedIn](#) | [YouTube](#)

From: Amores, Daniela (MDT) [<mailto:damores@miamidade.gov>]
Sent: Wednesday, May 20, 2015 1:01 PM
To: Claudia Diaz; Wilson, Carol (MDT)
Subject: RE: Mary Brickell Village - Review

Hi Claudia,

Long time no talk. No, there would be no Metrorail Traction Power conflicts in the area you reference of SW 11 Street between SW 1 Ave and South Miami.

Carol,

Did anyone from Mover provide comments? Mover is directly above the area identified by Claudia.

Also, would you happen to know what contract is doing the digging at 8th street?

Regards,

Daniela Amores, Chief

Traction Power & Train Control

From: Claudia Diaz [<mailto:claudia.diaz@tylin.com>]

Sent: Wednesday, May 13, 2015 4:39 PM

To: Wilson, Carol (MDT)

Cc: Amores, Daniela (MDT)

Subject: RE: Mary Brickell Village - Review

We could add this note only if it applies to our area SW 11 St between SW 1 Ave and South Miami Avenue otherwise we would be misguiding the contractor.

The picture is for SW 8 St and SW 1 Ave.

Please let me know if this still applies to our Project.

Sincerely,

Claudia Diaz, P.E.

Transportation Engineer

TYLIN INTERNATIONAL

201 Alhambra Circle, Suite 900

Coral Gables, FL 33134

305.567.1888 (Main)

305.714.4018 (Direct)

305.567.1771 Fax

claudia.diaz@tylin.com

Visit us online at www.tylin.com

[Twitter](#) | [Facebook](#) | [LinkedIn](#) | [YouTube](#)

From: Wilson, Carol (MDT) [<mailto:carolw@miamidade.gov>]

Sent: Wednesday, May 13, 2015 4:32 PM

To: Claudia Diaz

Cc: Amores, Daniela (MDT)

Subject: FW: Mary Brickell Village - Review

Claudia, see Daniela Amores comments below! Can the notes be revised to advise the contractor that MDT tractor power conduits with cables are in the area. Extreme precaution is to be taken when digging, trenching or boring near these duct banks. In fact, these conduits are to be shown and identified on the plans. Regards!

From: Amores, Daniela (MDT)

Carol,

There are existing Traction Power conduits in the proposed work area. Traction Power Supervisor has spoken with the contractor and made them aware of these conduits.

Regards,

Daniela Amores, Chief
Traction Power & Train Control
Miami Dade Transit
6601 N.W. 72nd Ave
Miami, Florida 33166
305.884.7502 direct
786.879.0466 mobile
damores@miamidade.gov

From: Wilson, Carol (MDT)

Sent: Tuesday, May 12, 2015 11:42 AM

To: Amores, Daniela (MDT); Arenes, German A. (MDT); Baez, Froilan I. (MDT); Blackman, Jerry (MDT); Bryan, Gerald E. (MDT); Cejas, Monica (MDT); Burgos, Jose (MDT); Gordon, Derrick (MDT); Liptrot, Duane (MDT); de la Nuez, Jose (MDT); Lee, Alvin (MDT); McClellan, Robert (MDT); Mondesir, Daniel (MDT); Muntan, Eric (MDT); Perez, Rosie (ITD); Palenzuela, Lazaro (MDT); Padron, Isabel (MDT); Perez, Joel (MDT); Palenzuela, Lazaro (MDT)

Cc: Aleman, Orlando (MDT); Aguilar, Ricardo (MDT); Alfonso, Miguel (MDT); Armorer, Colin (MDT); Auld, James (MDT); Baldwin, Dwight (MDT); Baker, Lazavia (MDT); Capote, Orlando D. (MDT); Carbonell, Jose (MDT); Cartaya, Nilia M. (MDT); Corzo, Maria (MDT); Dallas, Cedric (MDT); Damian, Karla (MDT); Davis, Lenard B. (MDT); Day, Randy (MDT); Fernandez, Wilfredo M. (MDT); Fletcher, Winston (MDT); Gordon, Renessa (MDT); Gipson, Dwight (MDT); Habibnejad, Hossin (MDT); Heisler Jr., James (MDT); Hernandez, Hector (MDT); Hernandez, Javier (MDT); Hermida, Felipe (MDT); Maldonado, George (MDT); Interian, Leo (MDT); Kunath, Eva (MDT); de la Nuez, Jose (MDT); Macias, Willy (MDT); Machin, Angel (MDT); Molina, Rene (MDT); Mori, Miguel (MDT); Nelson, William (MDT); Ortega, Marcos (MDT); Perez, Nury E. (MDT); Rasheed, Ahmed (MDT); Rincon, Juan Carlos (MDT); Rodriguez, Malka (MDT); Rodriguez, Mario (MDT); Rodriguez, Raonel (MDT); Robinson, Douglas K. (MDT); Robinson, Gregory (MDT); Salmon, Javier (MDT); Sanchez, Julia (MDT); Sharifi, Akbar (MDT); Smerling, Barry (MDT); Spinelli, Miguel (MDT); Sumoski, James (MDT); Texidor, William (MDT); Vardanian, Garegin (MDT); Vega, Lee (MDT); Villarmarzo, Jose (MDT); Walker, Eric (MDT); Wedderburn, Dean (MDT); White, James (MDT); Wilt, Carl (MDT); Zahn, Eric (MDT)

Subject: FW: Mary Brickell Village - Review

Good morning staff:

The City of Miami is proposing a drainage and roadway project in the vicinity of Mary Brickell Village area. A portion of the project may impact the Miami-Dade Transit (MDT) system particularly in the area with the Metromover and/or buses. Please review the plans and provide comments by 5/20/15. If I do not hear from you by the due date, it will be assumed that you are in agreement with the plans as proposed.

Regards!

Carol A. Wilson, PLS
Manager, right-of-Way engineering
Miami-Dade Transit
701 NW 1st Court, 15th Floor
Miami, Florida 33136
Tel. 786-469-5278

“Delivering Excellence Everyday”

From: Claudia Diaz [<mailto:claudia.diaz@tylin.com>]
Sent: Thursday, April 30, 2015 1:59 PM
To: Wilson, Carol (MDT)
Cc: Misas, Orlando; Lago, Jose
Subject: Mary Brickell Village - Review

Good Afternoon Carol,

I am working with the City of Miami on a project along SW 11 Street from SW 1 Avenue to South Miami Avenue. Since the project is adjacent to the Metro Mover Orlando Misas has requested to send you the plans for your review and approval.

I have attached the signed and sealed plans. Please let me know if you need hard copies in order to review them or if I need to get you any other document.

The City wants to start the bid process by June 1. We would really appreciate your input and assistance.

Thanks in advance for your time.

Sincerely,

Claudia Diaz, P.E.
Transportation Engineer
TYLIN INTERNATIONAL
201 Alhambra Circle, Suite 900
Coral Gables, FL 33134
305.567.1888 (Main)
305.714.4018 (Direct)
305.567.1771 Fax
claudia.diaz@tylin.com
Visit us online at www.tylin.com
[Twitter](#) | [Facebook](#) | [LinkedIn](#) | [YouTube](#)