

C 11/16/15 @ 12:21

Department of Regulatory and Economic Resources
Miami-Dade County
Plan Review Summary

Process Number: PAVING &
DRAINAGE REVIEW

FINAL CORE REVIEW DATE: 11/16/2015

OVERALL STATUS: Overall Approval

PROJECT DETAILS:

FOLIO: 01-0207-010-1011

ADDRESS: SW 1 AVE FROM SW 7 STREET TO

PERMIT TYPE DESC.:

CONTACT DETAILS:

NAME: YURIEL ADDINE

EMAIL: YADDINE@AOCTE.COM

PHONE #: 7868737854

DISAPPROVAL CODES:

TASK	REVIEWED BY	STATUS DATE	STATUS
Initial Core Review	Julio Diaz	11/10/2015	Reviewed

Comments: PERMIT FOR DRAINAGE IMPROVEMENTS/MILLING RESURFACING WORK. (CITY OF MIAMI PROJECT #B-30833)

SW 1 AVE FROM SW 7 ST TO SW 15 RD.

3-SETS OF PLANS SUBMITTED.

SHEETS #1 TO #13/2 #15 SHEETS AND #16 TO #19 ONLY PLUSE ONE BINDER.

FOLIO # USED FOR REFERENCE ONLY.

POLLUTION REMEDIATION SECTION SIGNED N/A.

PAVING AND DRAINAGE SECTION APPROVED.

DERM STAMP PLACED ON COVER SHEET #1.

P D Review	Kaheill S Whittaker	11/13/2015	Approved
------------	---------------------	------------	----------

Comments: Plans have been reviewed for compliance with environmental requirements for storm water disposal. Water Control has no objections to the proposed scope of work. However, a DERM Class V Permit will be required for any temporary or emergency dewatering activities during the construction of the proposed project.

POLREM Review	Gabriel Garcia	11/12/2015	N/A
---------------	----------------	------------	-----

Comments: HWR-779

N/A

No contamination in vicinity of proposed work.

Final Core Review	Julio Diaz	11/16/2015	Overall Approval
-------------------	------------	------------	------------------

PLAN CONDITIONS:

NO CONDITIONS

PLAN REVIEW FEES (FEES ARE SUBJECT TO CHANGE PENDING FINAL APPROVAL):

FEE CODE	DESCRIPTION	USER	DATE	UNIT	TOTAL
Total					

FOR MORE INFORMATION PLEASE CONTACT: