



City of Miami

ADDENDUM No. 1

March 30, 2018

INVITATION TO BID No.: 17-18-008

MIAMI WOMAN'S CLUB BAYWALK PROJECT, D2

OFFICE OF CAPITAL IMPROVEMENTS PROJECT No.: B-30731

TO: ALL PROSPECTIVE BIDDERS:

The following changes, additions, clarifications, and/or deletions amend the above-captioned Invitation to Bid (ITB) and shall become an integral part of the Bid submitted and the Contract to be executed for **Miami Woman's Club Baywalk Project, D2 – ITB No.: 17-18-008** (the "Project"). Please note the contents herein and affix same to the documents you have on hand.

All attachments (if any) are available on the Office of Capital Improvements (OCI) website and are part of this Addendum.

Requests for Information – Since Issuance of ITB No. 17-18-008:

- Q1. Unable to find any details or specs for the Pedestrian Railing, Item No. 13, please provide?
A1. See Exhibit No. 1 – FDOT Standard Index No. 862.
- Q2. What will be the color of the concrete sidewalk (Baywalk)?
A2. Baywalk shall be colored concrete with Scofield's color C-12 (Mesa Beige) in accordance with the Miami River Greenway Regulatory Design Standards, dated July 2005. Integral color shall be pure mineral oxide, lime proof, and non-fading.

THIS ADDENDUM IS AN ESSENTIAL PORTION OF THE CONTRACT DOCUMENT AND SHALL BE MADE A PART THEREOF.

Annie Perez, CPPO, Director
Department of Procurement, City of Miami