



City of Miami

ADDENDUM No. 2
December 18, 2019

INVITATION TO BID No.: 19-20-009
NW 24TH AVENUE, NW 25TH AVENUE, AND NW 32ND STREET ROAD
IMPROVEMENTS, D1
PROJECT B-30723

TO: ALL PROSPECTIVE BIDDERS:

The following changes, additions, clarifications, and/or deletions amend the above-captioned Invitation to Bid (ITB) and shall become an integral part of the bid submitted and the Contract to be executed for **NW 24th Avenue, NW 25th Avenue, and NW 32nd Street Road Improvements – D1 – ITB No.: 19-20-009** (the “Project”). The remaining provisions are now in effect and remain unchanged. Please note the contents herein and affix same to the documents you have on hand.

All attachments (if any) are available on the Office of Capital Improvements (OCI) website and are part of this Addendum.

MODIFICATIONS

- A) The **Bid Submission Due Date** is hereby extended to January 6, 2020 at 2:00 p.m.
- B) Geotechnical Report attached.
- C) Revision #1 attached.

REQUESTS FOR INFORMATION - SINCE ISSUANCE OF ITB No. 19-20-009

- Q1. In the General Terms and Conditions, page 32, item 23 the bid calls for a full-time Superintendent. Is it mandatory to be full-time?
A1. **Yes.**

- Q2. Do you have Geotechnical Report?
A2. **Yes, please see attached Geotechnical Report.**

- Q3. What is the thickness of the asphalt to be removed?
A3. **Please see Geotechnical Report for information requested. Field Testing-Pavement Cores, Page 3; Pavement Core No. C-1, Page 14; Pavement Core No. C-2, Page 15.**

- Q4. The plans call for removal of drainage structures and pipe but it is very difficult to quantify the length of the French Drain and Solid Pipes. Can the City add an item for this job?
A4. **No, Removal of existing drainage system to be included in the price for Pay item # 110-**

1-1 Clearing and Grubbing.

-
- Q5.** Do the Curbs Type F and Valley Gutter have a base pad (4" limerock) or does the quantity of the base in the spreadsheet include the quantity under the curbs? Please advise.
- A5.** **The spreadsheet quantity includes the 4" limerock base under proposed Type F and Valley Gutters.**
-
- Q6.** The drawings call for Planters, but apart from the concrete curbs, what does the Contractor need to do there? Place top soil and what else?
- A6.** **Special Details sheet in the plans require regrading and placement of sod in these areas.**
-
- Q7.** What is the scope of work for the Item # 110-15 "Arborist Work?"
- A7.** **Arborist shall be present on site to monitor construction activities near existing trees and direct all root pruning/barrier and/or canopy trimming activities if necessary.**
-
- Q8.** The plans call for "Root Barrier Required" and it is also shown in the detail but we cannot quantify the total length of the root barrier. Please advise.
- A8.** **Please see Revision #1 attached.**
-
- Q9.** Could the City add an item for Temporary Striping?
- A9.** **Please see Revision #1 attached.**
-
- Q10.** The drawings say "2" gas main to be construction by others." That means that the new gas main is to be constructed while we are on site?
- A10.** **The 2" gas main is to be constructed by others prior to Contractor mobilizing on to site.**
-
- Q11.** What is the allowable contract time for this project?
- A11.** **In accordance with Section 3, Article 1 "Contract Time and Hours," "Contractor shall have three hundred (300) calendar days to achieve Substantial Completion from the date that the Notice to Proceed is issued. Contractor shall have an additional thirty (30) calendar days to achieve Final Completion of the Contract."**
-
- Q12.** What is the budgeted contract amount / engineer's estimate for this project?
- A12.** **City: \$1,009,000.00, Joint Participation Agreement ("JPA") with Miami-Dade Water and Sewer Department ("WASD"): \$339,000.00, Total = \$1,348,000.00.**
-
- Q13.** The ITB for project B-30723 requires prospective bidders to have a minimum of five (5) years' experience under its current business name, with three (3) similar project completions within the last five (5) years. To bolster the competitive process, and increase the pool of prospective bidders, can this requirement be reduced to three (3) years of experience under its current business name with three (3) similar projects completed within the last three (3) years? Alternatively, can the experience and work history of key project and ownership personnel, gained during construction of projects prior to their involvement/employment with the prospective bidders be used to satisfy this requirement?
- A13.** **The City has decided not to change any of the requirements.**
-

THIS ADDENDUM IS AN ESSENTIAL PORTION OF THE CONTRACT DOCUMENT AND SHALL BE MADE A PART THEREOF.



**Annie Perez, CPPO, Director
Department of Procurement, City of Miami**